WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91407
Permit No.
Basin 212

NOTICE OF INTENT NO. 21131

1. OWNER CLARK CO.
MAILING ADDRESS 500 S. GRAND CENTRAL PKY
LAS VEGAS, NEVADA 89155

ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ SE ¼ Sec. 27 T. 21 N/S R. 62 E. CLARK County
PERMIT NO. DW 1155 (Issued by Water Resources) 161-27-896-002 (Parcel No.) NA (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic DEWATER ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other BUCKET

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| INTENT TO DRILL | | 30 | WELLS | |
| ONLY 18 COMPLETED @ | | THIS | TIME | |
| CLAY W/ GRAVEL LENSES. | | 0 | 32 | 32 |

Date started FEBRUARY 10, 2003 19
Date completed JULY 10, 2003 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 32 Feet Depth Cased 32 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 20 Inches | 0 Feet | 32 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 12 | 14 | .250 | 0 | 12 |
| | | | | |
| | | | | |

Perforations:
Type perforation LOUVERED
Size perforation .040
From 12 feet to 32 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 10'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 10 feet to 32 feet

9. WATER LEVEL
Static water level 6 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name KELLEY DEWATERING CONSTRUCTION CO. (Contractor)
Address 5175 CLAY (Contractor)
WYOMING, MICH 49548
Nevada contractor's license number issued by the State Contractor's Board ABDS 2149
Nevada driller's license number issued by the Division of Water Resources, the on-site driller S0326
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 10-3-03

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627