

OFFICE USE ONLY
 Log No. 91423
 Permit No. _____
 Basin. 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23599

1. OWNER John Glickburg (Village Properties) ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 121 Spear St. #250 San Francisco, CA 94150 ADDRESS 6040 W. Spring Mtn Rd. Las Vegas, NV
 2. LOCATION SW 1/4 NW 1/4 Sec. 13 T. 21 N. 60 E. County Clark
 PERMIT NO. 163-13-101-005 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
- Slightly Cemented sands & Gravel		0	32	32
- brown clay		32	41	9
- Cemented sands & gravel		41	70	29
- Sands & Gravel		70	90	20
DOWN/DOWN RECEIVED				
DEC 11 2003				
LAS VEGAS CONTRACTOR				

8. WELL CONSTRUCTION
 Depth Drilled 90 Feet Depth Cased 90 Feet
 HOLE DIAMETER (BIT SIZE)
 From 8.75 Inches To 0 Feet 90 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>	<u>SCH 40</u>	<u>PVC</u>	<u>0</u>	<u>60</u>

Perforations:
 Type perforation Factory Slotted
 Size perforation .020
 From 60 feet to 90 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 58 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 58 feet to 90 feet

9. WATER LEVEL
 Static water level 80' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Western Technologies Inc Contractor
 Address 3611 W. Tompkins Ave Contractor
Las Vegas, NV 89103
 Nevada contractor's license number NVPE14435
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller. 2057
 Signed [Signature]
 By _____ driller performing actual drilling on site or contractor
 Date 12-17-03

Date started 11-19-2003
 Date completed 11-20-2003

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			