

Log No. 914.32  
 Permit No. \_\_\_\_\_  
 Basin 107

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 49608

1. OWNER ~~DA DeLuca~~ ADDRESS AT WELL LOCATION 21 Desert View  
 MAILING ADDRESS Perry Urton

2. LOCATION NW 1/4 NW 1/4 Sec. 22 T. 11 N/S R. 24 E County \_\_\_\_\_  
 PERMIT NO. 9-151-04 Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

| Material            | Water Strata | From | To  | Thick-ness |
|---------------------|--------------|------|-----|------------|
| SAND                |              | 0    | 18  | 18         |
| STREAKY GRAVEL SAND |              | 18   | 61  | 43         |
| BROWN STICKY CLAY   |              | 61   | 125 | 64         |
| SAND                | X            | 125  | 136 | 11         |
| BROWN CLAY-GRAVEL   | X            | 136  | 195 | 59         |
| LARGE GRAVEL        | X            | 195  | 235 | 40         |

8. WELL CONSTRUCTION  
 Depth Drilled 235 Feet Depth Cased 235 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 0 Feet 235 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet)  |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 5/8</u>       | <u>14</u>           | <u>.188</u>             | <u>+1</u>   | <u>235</u> |

Perforations:  
 Type perforation Factory milled  
 Size perforation 3/32" X 3"  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 215 feet to 235 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 56 ft  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 56 feet to 235 feet

9. WATER LEVEL  
 Static water level 97 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality CLEAR

Date started 17 NOV 2003  
 Date completed 21 NOV 2003

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

| G.P.M.     | Draw Down (Feet Below Static) | Time (Hours) |
|------------|-------------------------------|--------------|
| <u>25+</u> |                               | <u>1.0</u>   |

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name \_\_\_\_\_ Contractor  
 Address \_\_\_\_\_ Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 46498  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167  
 Signed Jack Watson  
 By driller performing actual drilling on site or contractor  
 Date \_\_\_\_\_