WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91436
Permit No.
Basin 209

NOTICE OF INTENT NO. 25713

1. OWNER Alamo Sewer - Water
MAILING ADDRESS P.O. Box 418 Alamo NV 89001
ADDRESS AT WELL LOCATION One mile south on Paradise Road Alamo NV

2. LOCATION N/W ¼ N/W ¼ Sec. 8 T. 7 N/S R. 61 E. Lincoln County
PERMIT NO. — Issued by Water Resources | Parcel No. NA | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
No Log available on this well. perforate with mills knife from bottom of well 168' to 20 which is 50' above static water level				
Set 105' 4" tremie pipe and 54' 3" tremie pipe on bottom				
Poured approximately 5% more neat cement than hole required				
270 gals water with 52 bags cement. some water was displaced out top of well but most of it went out thru new perforations				

Date started 10-15-03, 19
Date completed 10-16-03, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled Unknown Feet Depth Cased 168 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
Unknown	Inches	Feet	Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	168

Perforations:
Type perforation Unknown
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal 168'
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling and Pumps (Contractor)
Address HC 61 Box 54 (Contractor)
Hiko NV 89017
Nevada contractor's license number issued by the State Contractor's Board 0028966
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1191
Signed Mike Davis
By driller performing actual drilling on site or contractor
Date 10-16-03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627