WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91439
Permit No.
Basin 087

NOTICE OF INTENT NO. 54484

1. OWNER Friedrich E. Stoll
MAILING ADDRESS 4955 Mt. Rose Hwy
Reno, NV 89511

ADDRESS AT WELL LOCATION 4955 Mt. Rose Hw

2. LOCATION NW 1/4 NW 1/4 Sec. 36 T 18N N/S R 19E E Washoe County
PERMIT NO. ____ Issued by Water Resources
150-212-03 Parcel No.
Subdivision Name

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we abandoned a 8 5/8" x 136' deep water well. We perforated from bottom to surface at 4 around and at one foot intervals. Water level was 134' so we poured approximately 3 cu. yards of neat cement mixted 5.2 gallons/sack and filled the well to the top. We cut the top two feet of casing off the well.				
Washoe Count Permit #WL030221				

Date started 12/5/2003 , 19__
Date completed 12/5/2003 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 136 Feet Depth Cased 136 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	18	.188	0	136

Perforations:
Type perforation Mills Knife
Size perforation Puncture
From 134 feet to Surface feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Gravel Packed: [ ] Yes [X] No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 134 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc. Contractor
Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 12/5/03

USE ADDITIONAL SHEETS IF NECESSARY