

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25206

1. OWNER LAS Vegas Valley Water Dist. ADDRESS AT WELL LOCATION ECHO RD.  
 MAILING ADDRESS 1001 S. Valleyview Blvd. Kyle Canyon  
LAS Vegas N.V. 89153

2. LOCATION SW 1/4 NE 1/4 Sec. 26 T. 19 N. R. 56 E Clark County  
 PERMIT NO. 12926801002 PH 696377 Kyle Canyon Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other     

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other     

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>GRAVELS Cobbles</u>		<u>0</u>	<u>212</u>	<u>212</u>
<u>Silts Boulders</u>				
<u>Some Cemented Sands</u>				
<u>Limestone</u>		<u>212</u>	<u>320</u>	<u>108</u>
<u>See Att. Lithos</u>				

RECEIVED  
 03 AUG 11 PM 12:55  
 STATE ENGINEERS OFFICE

DCNR/DWR  
 RECEIVED  
 JAN 16 2004

LAS VEGAS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 320 Feet Depth Cased None Feet

HOLE DIAMETER (BIT SIZE) ABANDONED  
 From 0 Feet To 320 Feet  
6 1/4 Inches 0 Feet 320 Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 320-0  
 Neat Cement  
 Placement Method:  Pumped 640s.  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 85 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 10°C Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Boylek Drilling Inc 5555. Hanba Contractor  
 Address 5555. Hanba Blvd. Contractor  
LA Hanba Co.  
 Nevada contractor's license number issued by the State Contractor's Board 0067055A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2145  
 Signed MM  
 By driller performing actual drilling on site or contractor  
 Date 7-4-03

Date started 6-3-03, 20\_\_\_\_  
 Date completed 6-20-03, 2003

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>R.C.</u>	<u>2004</u>	<u>UK</u>	