

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25908

1. OWNER Pat Richards ADDRESS AT WELL LOCATION Mile west of S  
 MAILING ADDRESS 529 Clayton St North US 33 Lincoln County NV  
Las Vegas NV 89032  
 2. LOCATION S/4 1/4 S/E 1/4 Sec. 24 T. 11 N. R. 62 E. Lincoln County  
 PERMIT NO. 8201-12 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand Gravel</u>		<u>0</u>	<u>25</u>	<u>25</u>
<u>Reddish Clay-silt</u>		<u>25</u>	<u>21</u>	<u>13.5</u>
<u>Sand-Gravel-Boulders</u>		<u>21</u>	<u>46</u>	<u>25</u>
<u>Fine sand clay</u>		<u>46</u>	<u>56</u>	<u>10</u>
<u>Sand-Gravel-Boulders</u>		<u>56</u>	<u>69</u>	<u>13</u>
<u>Sand-Gravel-Silt</u>	<input checked="" type="checkbox"/>	<u>69</u>	<u>71</u>	<u>12</u>
<u>Sand-Gravel-Boulders</u>	<input checked="" type="checkbox"/>	<u>71</u>	<u>85</u>	<u>4</u>
<u>Barite chys from 56' to 58'</u>				

8. WELL CONSTRUCTION  
 Depth Drilled 85 Feet Depth Cased 82 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 8 3/4 Inches To 0 Feet 85 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>		<u>sch 40</u>	<u>0</u>	<u>82</u>

Perforations:  
 Type perforation factory  
 Size perforation 20 # hole screen  
 From 62 feet to 82 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 56  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 58 feet to 85 feet

9. WATER LEVEL  
 Static water level 65 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 51 °F Quality Good

Date started 12-20-03, 19\_\_\_\_\_  
 Date completed 12-22-03, 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>NA</u>			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Davis Drilling and Pumps Contractor  
 Address HC 61 Box 59 Contractor  
Hiko NV 89017  
 Nevada contractor's license number issued by the State Contractor's Board 0028966  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191  
 Signed 12-20-03  
 By driller performing actual drilling on site or contractor  
 Date 12-20-03

0w-4