WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91479
Permit No. [redacted]34
Basin 069 / 69422-3

NOTICE OF INTENT NO. 31536

1. OWNER Winnemucca Farms #5
MAILING ADDRESS 1 Potato Place
Winnemucca NV
ADDRESS AT WELL LOCATION Golconda Butte

2. LOCATION SW ¼ SW ¼ Sec. 14 T. 37 N R. 39 E Humboldt County
PERMIT NO. [redacted]34 / 69422-3 (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	17	
Sand & pea gravel		17	94	
Ben Clay & Bulat Clay		94	110	
Sand & pea gravel		110	115	
Brown Clay		115	119	
Sand		119	123	
Clay		123	125	
Sand		125	128	
Clay & Sand mix		128	160	
Sand		160	164	
Clay		164	180	
Brown & Tan Clay		180	200	
Brown Clay w/ Sand stks		200	256	
Sand & pea gravel		256	260	
Brown Clay w/ Sand stks		260	320	
Sand		320	332	
Bolder		332	335	
Basalt		335	400	
Reddish Brown Basalt		400	418	
Black Basalt		418	428	
Brownish Basalt		428	430	
Basalt		430	443	
Hard Burnt Clay		443	460	
Broken Rock & Clay		460	515	
Broken Rock		515	576	
N 41.076332				
W 117.563508 NAD83				

Date started 10-1-02, 19
Date completed 10-15-02, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Not Available yet		

8. WELL CONSTRUCTION
Depth Drilled 576 Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
26" Inches	0 Feet	576 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
18"		.375	+2	294
10"		.250	334	460

Perforations:
Type perforation .040 / 1/3" pay
Size perforation 18" / 10"
From 294 feet to 334 feet
From 460 feet to 576 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50' feet to 576' feet

9. WATER LEVEL
Static water level 43 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Riverside Inc. (Contractor)
Address P.O. Box 720 (Contractor)
Parma Id. 83660
Nevada contractor's license number issued by the State Contractor's Board 0044881
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2109
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 10-30-02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627