



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 51383

1. OWNER Frehner Construction Co., Inc. ADDRESS AT WELL LOCATION NDOT Material Site WP34-1
 MAILING ADDRESS 4040 Frehner Road
North Las Vegas, Nevada 89030

2. LOCATION SE 1/4 SW 1/4 Sec 18 T 15 N 8 R 64 E White Pine County
 WELL NO. C-220 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 ~~Municipal~~ Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Unknown

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Abandonment Procedure as follows:				
Set tremie pipe @ 375 Ft. pumped 648 Gals. (49 sacks) Aquaguard grout down hole. Unable to tag grout at all.				
Poured 124 (50 lb bags) pellets		376	100	276
Concrete grout		100	0	100

8. WELL CONSTRUCTION
 Depth Drilled 376 Feet Depth Cased Unknown Feet

HOLE DIAMETER (BIT SIZE)
 From To
Unknown Inches..... Feet..... Feet
 Inches..... Feet..... Feet
 Inches..... Feet..... Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8-5/8	22.36	.250	0	Unknown

Perforations:
 Type perforation Unknown
 Size perforation Unknown

From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet

Surface Seal: Yes No Seal Type:
 Depth of Seal Unknown Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No Unknown
 From..... feet to..... feet

9. WATER LEVEL
 Static water level 170 feet below land surface
 Artesian flow..... G.P.M..... P.S.I.
 Water temperature Cold °F Quality Unknown

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc. Contractor
 Address 557 Ely Avenue Contractor
Ely, Nevada 89301
 Nevada contractor's license number issued by the State Contractor's Board 14790
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793
 Signed Rick Lewis By: Lowell D. Christiansen
 By driller performing actual drilling on site or contractor
 Date December 19, 2003

Date started December 11, 2003
 Date completed December 17, 2003

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Unknown			

RECEIVED
 DEC 22 PM 1:22
 STATE ENGINEER'S OFFICE