WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91536
Permit No.
Basin 179

NOTICE OF INTENT NO. 51384

1. OWNER Frehner Construction Co., Inc.
MAILING ADDRESS 4040 Frehner Road
North Las Vegas, Nevada 89030

ADDRESS AT WELL LOCATION NDOT Material Site WP10-35

2. LOCATION SW ¼ SE ¼ Sec 34 T 14 N/S R 64 E White Pine County

~~PERMIT~~ Water NO. C-220 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ ~~Municipal~~/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Unknown

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Abandonment Procedure as Follows:				
Set tremie pipe @ 149 Ft. pumped 329 Gals. (21 sacks) Aquaguard grout down hole filled		150	61	89
Poured 21 (50 lb bags) 3/8" Bentonite pellets		61	20	41
Concrete grout		20	0	20

Date started December 11, 2003
Date completed December 17, 2003

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Unknown			

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased Unknown Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Unknown Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8-5/8	22.36	.250	0	Unknown

Perforations:
Type perforation Unknown
Size perforation Unknown
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal Unknown
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No Unknown
From feet to feet

9. WATER LEVEL
Static water level 34 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Christiansen Drilling, Inc. (Contractor)
Address 557 Ely Avenue (Contractor)
Ely, Nevada 89301

Nevada contractor's license number issued by the State Contractor's Board 14790

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793

Signed Rick Lewis By Jerald D. Christiansen
By driller performing actual drilling on site or contractor

Date December 19, 2003

RECEIVED 2003 DEC 22 PM 1:22 STATE ENGINEER'S OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627