WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91533
Permit No.
Basin 230

NOTICE OF INTENT NO. 25650

1. OWNER Andy Gudas
MAILING ADDRESS P.O. Box 243
Amargosa Valley, Nv, 89020

ADDRESS AT WELL LOCATION
858 N. T+T Rd.
Amargosa Valley NV, 89020

2. LOCATION SW ¼ NW ¼ Sec. 18 T. 16 N/S R. 49 E. NYE County

PERMIT NO. _____ Issued by Water Resources | 19-211-08 Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
snd. + gravel		0	80	80
tan clay w/gravel layers		80	125	45
limestone		125	133	8
silt snd.		133	143	10
limestone		143	148	5
gravel	1st	148	165	17
limestone		165	175	10
snd. w/gravel		175	195	20
brown cly.		195	220	25
gravel w/snd.	2nd	220	245	25
limestone		245	250	5
Bottom of Well			250	

11/13/03

Plugging of well - Intent # ~~10062~~ 25651
Probe 6" steel well to depth of 138' - all dry. Could not perforate due to all-well cement seal. Poured 1 yd. neat cement from 20' - 138'. Poured concrete grout 0-20'.

Date started 11/7, 2003
Date completed 11/12, 2003

DCNR/DWR RECEIVED DEC 1 2003 LAS VEGAS OFFICE

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	250 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	PVC		0	250
Surface Protective casing:				
8	steel	.188		7

Perforations:
Type perforation Machined
Size perforation 6R .032 Screen; * 4R 1/8"x3" Every 12"
From * 150 feet to 160 feet
From 160 feet to 200 feet
From * 200 feet to 240 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☐ Neat Cement
☐ Cement Grout
☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 250 feet

9. WATER LEVEL
Static water level 138' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cook Drilling Co. Contractor
Address HC 70 Box 543 Contractor
Amargosa Valley, Nv. 89020
Nevada contractor's license number issued by the State Contractor's Board 5376-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2160
Signed [signature] By driller performing actual drilling on site or contractor
Date 12/1/03

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627