WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91535
Permit No.
Basin 230

NOTICE OF INTENT NO. 25652

1. OWNER Lisle Lowe
MAILING ADDRESS H.C. 69 Box 400 E. Amargosa Valley, Nv. 89020
ADDRESS AT WELL LOCATION 960 N. Dynamite Amargosa Valley, Nv. 89020

2. LOCATION NE ¼ NW ¼ Sec. 14 T. 16 N/S R 49 E NYE County
PERMIT NO. Issued by Water Resources | Parcel No. 19-571-51 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
large gravel w/snd		0	100	100
sndy. cly.		100	120	20
compacted gravel w/snd. layers		120	184	64
gravel w/snd.	1st	184	200	16
limestone		200	210	10
compacted gravel w/snd.		210	250	40
tan cly.		250	265	15
limestone		265	275	10
Bottom of Well			275	

DCNR/DWR RECEIVED DEC 1 2003 LAS VEGAS OFFICE

Date started 11/20, 2003
Date complated 11/25, 2003

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 275 Feet Depth Cased 275 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	275 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	PVC		0	275
Surface Protective Casing:				
8	steel	.188		7

Perforations:
Type perforation Machined
Size perforation 6R .032 Screen; * 4R 1/8" X 3" X 12"
From * 185 feet to 195 feet
From 195 feet to 235 feet
From * 235 feet to 265 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 275 feet

9. WATER LEVEL
Static water level 174 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cook Drilling Co. (Contractor)
Address H.C. 70 Box 543 (Contractor)
Amargosa Valley, Nv. 89020
Nevada contractor's license number issued by the State Contractor's Board 5376-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2160
Signed [signature] By driller performing actual drilling on site or contractor
Date 12/3/03

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627