


OFFICE USE ONLY  
 Log No. 91537  
 Permit No. \_\_\_\_\_  
 Basin 230



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25649

1. OWNER Douglas Sly ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS Hc 70, Box 445 3335 Sly Circle  
Amargosa Valley, NV 89020 Amargosa Valley, NV 89020  
 2. LOCATION NW 1/4 SE 1/4 Sec. 7 T 16 N 48 E County NYE  
 PERMIT NO. 19-041-84 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
large gravel w/snd		0	55	55
snd.		55	65	10
gravel w/snd		65	112	47
com. packed gravel w/snd layers		112	135	23
gravel w/snd	1st	135	152	17
limestone w/cly layers		152	178	16
snd. w/gravel	2nd	178	185	7
limestone w/cly		185	200	15
Bottom of well		200		

DCNE/DW/E  
 RECEIVED  
 NOV 17 2003  
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 0 Feet  
 From 0 Feet To 200 Feet  
 From \_\_\_\_\_ Inches To \_\_\_\_\_ Feet  
 From \_\_\_\_\_ Inches To \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>PVC</u>		<u>0</u>	<u>200</u>
Surface Protective Casing				
<u>8</u>	<u>Steel</u>	<u>.188</u>	<u>7</u>	<u>7</u>

Perforations:  
 Type perforation Machined  
 Size perforation GR. 22 screen \* 4R 1/8 x 3 x 12  
 From 130 feet to 140 feet  
 From 140 feet to 180 feet  
 From 180 feet to 190 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 200 feet

9. WATER LEVEL  
 Static water level 123 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Cook Drilling Co. Contractor  
 Address Hc 70 Box 543 Contractor  
Amargosa Valley, NV 89020  
 Nevada contractor's license number issued by the State Contractor's Board 5376-A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2160  
 Signed Randy Johnson  
 By driller performing actual drilling on site or contractor  
 Date 11/03/03

Date started 10/30/03, 20 \_\_\_\_  
 Date completed 11/02/03, 20 \_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)