

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 490821

1. OWNER Dave Zahradnik ADDRESS AT WELL LOCATION 205 Chaparral Drive  
 MAILING ADDRESS \_\_\_\_\_ Smith Valley, N.Y.  
 2. LOCATION NW 1/4 SW 1/4 Sec 25 T 11 N/S R 29 E Wyon County  
 PERMIT NO. 09-157-01 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other well

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Sand</u>		<u>0</u>	<u>3</u>	
<u>Clay</u>		<u>3</u>	<u>70</u>	
<u>Coarse</u>		<u>70</u>	<u>103</u>	
<u>Thin Clay</u>		<u>103</u>	<u>131</u>	
<u>Coarse Sandstone</u>		<u>131</u>	<u>178</u>	
<u>Thin Clay</u>		<u>178</u>	<u>187</u>	
<u>Sand silt</u>		<u>187</u>	<u>231</u>	
<u>Thin Clay</u>		<u>231</u>	<u>270</u>	
<u>Fine Sand</u>		<u>270</u>	<u>305</u>	
<u>Thin Clay</u>		<u>305</u>	<u>320</u>	
<u>Coarse Sand</u>		<u>320</u>	<u>340</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 340 Feet Depth Cased 340 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 To 340  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.75</u>	<u>13.00</u>	<u>3/16</u>	<u>1</u>	<u>20</u>
<u>6.75</u>	<u>3.00</u>	<u>3/16</u>	<u>20</u>	<u>340</u>

Perforations:  
 Type perforation Self Seal  
 Size perforation \_\_\_\_\_  
 From 220 feet to 340 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 0.50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 340 feet

9. WATER LEVEL  
 Static water level 93 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 11-1-03  
 Date completed 11-4-03

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>50</u>	<u>6</u>	<u>PR</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge  
 Name Red Drilling Inc Contractor  
 Address P.O. Box 599 Contractor  
Silver Springs NV 87479  
 Nevada contractor's license number 0031891  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 10277  
 Signature [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 11-4-03