

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

office use only  
Log No. 91523  
Permit No. ....  
Basin 84

NOTICE OF INTENT NO 48501  
Silver Horse Road

1. OWNER **Reginald Bagube**  
MAILING ADDRESS **24201 Verde Place**  
**Lake Forest CA 92630**

ADDRESS AT WELL LOCATION

2. Location **SE 1/4 NE 1/4 Sec 24 T 22N R 21E**  
PERMIT NO. **PARCEL NO. 077-150-23**

**Washoe** County

SUBDIVISION NAME

3. WORK PERFORMED			4. PROPOSED USE			5. WELL TYPE		
<input checked="" type="checkbox"/> New Well	Replace	Recondition	<input checked="" type="checkbox"/> Domestic	Irrigation	Test	Cable	<input checked="" type="checkbox"/> Rotary	RVC
Deepen	Abandon	Other	Municipal/Industrial	Monitor	Stock	<input checked="" type="checkbox"/> Air	Other	Mud

6. LITHOLOGIC LOG				
Material	Water/Strata	From	To	Thick-ness
Red volcanic		0	42	42
Gray shale		42	48	6
White soap stone		48	59	11
Gray red volcanic rock.		59	180	121
Gray sand stone		180	320	140
Green shale & Green & black		320	391	71
Red volcanic rock.		391	434	43
White soap stone		434	461	27
Red volcanic rock		461	529	68
Gray clay		529	545	16
Red volcanic rock		545	572	27
	556			0

8. WELL CONSTRUCTION				
Depth Drilled		Depth Cased		
572 feet		572 feet		
HOLE DIAMETER (BIT SIZE)				
		From	To	
11	inches	0	feet	60 feet
8 3/4	inches	60	feet	572 feet
	inches		feet	feet
CASING SCHEDULE				
Size O.D.	Weight/Ft.	Wall Thickness	From	To
(Inches)	(Pounds)	(Inches)	(Feet)	Feet
6 5/8	12.94	188	+1 1/2	572
Perforations:				
Type Perforation	Factory			
Size perforation	3/32 x 3"			
From 520	feet to	580	feet	
From	feet to		feet	
From	feet to		feet	
From	feet to		feet	
From	feet to		feet	
Surface Seal		<input checked="" type="checkbox"/> YES	No	Seal Type:
Depth of Seal		94	feet	Neat Cement
				Cement Grout
				Concrete Grout
Gravel Packed:		<input checked="" type="checkbox"/> Yes	No	
From 94		feet to	572 feet	

9. WATER LEVEL			
0	Static water level	395	feet below land surface
0	Artesian flow	0	GPM 0 P.S.I.
0	Water Temperature	cold	Degrees F Quality

Date started **12-8 -03**  
Date completed **12-15 -03**

7. WELL TEST DATA			
TEST METHOD:	Bailer	Pump	x Air Lift
G.P.M.	Draw Down (Feet Below Static)		Time (hours)
15	45		
30	125		
35	175		

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name **McKay Drilling, Inc.**  
**2290 Pioneer Drive**  
**Reno, NV 89509**  
NV Contractors No. **14170**  
NV Driller's Lic (on site) **1261-TI**  
Signed Steve McKay  
By driller performing actual drilling on site or contractor  
Date **12-16 -03**

RECEIVED  
 04 JAN -2 AM 11:08  
 WASHOE COUNTY OFFICE