

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

office use only  
 Log No. 91574  
 Permit No. ....  
 Basin 84

NOTICE OF INTENT NO 8531  
**Curnow Canyon Rd 51562**

1. OWNER **Todd Miller**  
 MAILING ADDRESS **125 Rosetta Stone**  
**Sparks NV 89436**

ADDRESS AT WELL LOCATION

2. Location se 1/4 nw 1/4 Sec 4 T 21n R 21E  
 PERMIT NO. PARCEL NO. **077-480-04**

SUBDIVISION NAME

Washoe County

3. WORK PERFORMED			4. PROPOSED USE			5. WELL TYPE		
<input checked="" type="checkbox"/> New Well	Replace	Recondition	<input checked="" type="checkbox"/> Domestic	Irrigation	Test	Cable	<input checked="" type="checkbox"/> Rotary	RVC
Deepen	Abandon	Other	Municipal/Industrial	Monitor	Stock	Air	Other	<input checked="" type="checkbox"/> Mud

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thickness
DG		0	100	100
Soft white granite.		100	405	305
Clay & white granite.		405	610	205
Hard granite.		610	613	3
Fractured granite.	x	613	616	3
Clay white hard granite.		616	702	86
Hard granite with fractures..	x	702	745	43

8. WELL CONSTRUCTION				
Depth Drilled	745 feet	Depth Cased	745 feet	
HOLE DIAMETER (BIT SIZE)				
	From	To		
10	inches	0	feet	60
8 3/4	inches	60	feet	745
	inches		feet	feet
CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.94	188	+1 1/2	745
Perforations:				
Type Perforation	Factory			
Size perforation	3/32 x 3"			
From	310	feet to	330	feet
From	610	feet to	630	feet
From	705	feet to	745	feet
From		feet to		feet
From		feet to		feet
Surface Seal	<input checked="" type="checkbox"/> YES	No		Seal Type:
Depth of Seal	60	feet		Neat Cement
				<input checked="" type="checkbox"/> Cement Grout
				Concrete Grout
Gravel Packed:	<input checked="" type="checkbox"/> Yes	No		
From	60	feet to	745	feet
9. WATER LEVEL				
Static water level	300	feet below land surface		
Artesian flow	0	GPM	0	P.S.I.
Water Temperature	cold	Degrees F		Quality

Date started **11-10 -03**  
 Date completed **12-2 -03**

7. WELL TEST DATA			
TEST METHOD:	Bailer	Pump	x Air Lift
G.P.M.	Draw Down (Feet Below Static)		Time (hours)
3	100		
10	200		
15	430		
20	445		12

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **McKay Drilling, Inc.**  
**2290 Pioneer Drive**  
**Reno, NV 89509**  
 NV Contractors No. **14170**  
 NV Driller's Lic (on site) **1261 T1**  
 Signed Steve McKay  
 By driller performing actual drilling on site or contractor  
 Date **12-5 -03**

RECEIVED  
 04 JAN -2 AM 11:08  
 WATER RESOURCES OFFICE