

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25546

1. OWNER Springbrook LLC ADDRESS AT WELL LOCATION 4675 Cimron Rd.
 MAILING ADDRESS _____ Las Vegas, Nev. 89129

2. LOCATION NE 1/4 NW 1/4 Sec. 04 T 20S N/S R 60 Clark County
 PERMIT NO. 138-04-103-012 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Municipal/Industrial Irrigation Monitor Test Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
NAC 534-420 Section 8				
A Depth of Well - 480				
B. The depth to which the materials used to plug the well were placed 480 ft.				
C. The type size and location of the perforations which were made in the casing: Type - Knife Size - 2" x 1/8"				
Location - 4 times per foot 4 times around 480 up to 280 ft. Unable to perforate 8" pipe 6" pipe from 280 to 480 ft.				
D. The debris encountered: None				
E. Materials used to plug the well: 27 Sack neat cement. Section 9 Neat cement by tremie pipe in an upward direction.				
<u>Plugging of</u>				
<u>Log # 53480</u>				

8. WELL CONSTRUCTION
 Depth Drilled _____ Feet Depth Cased _____ Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
 Type perforation _____
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 220 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Vernon H. Dimick Contractor
 Address 5360 N. Bonita Vista St. Contractor
Las Vegas, Nev. 89149
 Nevada contractor's license number issued by the State Contractor's Board 10062
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
 Signed V. H. Dimick
 By driller performing actual drilling on site or contractor
 Date 12-17-03

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)