

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 91592
 Permit No. 36083
 Basin 104

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 52571

1. OWNER Carson City Utilities District (LV-5TH-03) ADDRESS AT WELL LOCATION 4351 Combs Canyon Road,
 MAILING ADDRESS 3505 Butti Way Carson City, NV.
Carson City, NV 89701

2. LOCATION NE 1/4 NE 1/4 Sec. 2 T 15N N/S R 19 E Carson City County
 PERMIT NO. 36083 Issued by Water Resources Parcel No. Lakeview Woods #2 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Hole was drilled as a water quantity and quality test hole. After all tests were done, hole was abandoned by pumping abantonite through the test rods to 80', then poured hole plug to 47', and capped with neat cement.				
Quantities Used:				
Cement: 16.5 cu.ft. Hole plug: 9.7 cu.ft Abantonite: 134 cu.ft.				
Alluvium		0	80	80
Granite		80	340	260
Brown/gray rock		340	520	180
Brown/white rock		520	540	20

64 JUN -2 AMT: 00
 CARSON CITY UTILITIES DISTRICT

Date started 12/6/2003, 19
 Date completed 12/12/2003, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>120</u>	<u>Not Meas.</u>	

8. WELL CONSTRUCTION
 Depth Drilled 540 Feet Depth Cased 83 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
<u>14.75</u>	<u>0</u>	<u>83</u>	<u>83</u>
<u>6.125</u>	<u>83</u>	<u>540</u>	<u>540</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8.625</u>	<u>28.55</u>	<u>0.322</u>	<u>0</u>	<u>83</u>

Perforations:

Type perforation _____
 Size perforation _____

From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 83' Cement Grout
 Placement Method: Pumped Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 36 feet below land surface
 Artesian flow N/A G.P.M. _____ P.S.I. _____
 Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling Contractor
 Address P.O. Box 5279 Contractor
Elko, NV 89802-5279
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2254
 Signed Daryl Hanzman
 By driller performing actual drilling on-site or contractor
 Date 12/29/03

B-STC