WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91595
Permit No.
Basin 101

NOTICE OF INTENT NO. 48686

1. OWNER Ed Gieratz
MAILING ADDRESS 1919 Hillsoboro Blvd
Fallon, NV

ADDRESS AT WELL LOCATION 1915 Hillsboror Blvd
Fallon, NV 89406

2. LOCATION SW 1/4 NE 1/4 Sec. 22 T 19 N/S R 28 E Churchill County
PERMIT NO. Issued by Water Resources | Parcel No. 8-231-04 | Subdivision Name

3. **WORK PERFORMED**
XX New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. **PROPOSED USE**
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. **WELL TYPE**
☐ Cable XX Rotary ☐ RVC
☐ Air ☐ Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Brown Sand		0	9	9
Brown Clay		9	19	10
Brown Sand		19	45	26
Brown Clay		45	47	2
Gray Sand		47	50	3
Gray Clay		50	54	4
Gray Sand		54	70	16
Gray Clay		70	73	3
Brown Sand	XX	73	79	6

RECEIVED
03 JUL 29 AM 11:02
STATE ENGINEERS OFFICE

Date started 7/7/03, 19__
Date completed 7/7/03, 19__

7. **WELL TEST DATA**
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. **WELL CONSTRUCTION**
Depth Drilled 79 Feet Depth Cased 79 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	79	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	20
6 PVC	3.92	.258	20	79

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 76 feet to 79 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 70
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 70 feet to 79 feet

9. **WATER LEVEL**
Static water level 19 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2212
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 7/14/03