

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24836

1. OWNER City of LV. Public Works ADDRESS AT WELL LOCATION 300 LV Blvd.
 MAILING ADDRESS 400 E. Stewart Ave
Las Vegas, NV 89101

2. LOCATION NW 1/4 NE 1/4 Sec 34 T. 20 N. R. 61 E Clark County

PERMIT NO. 139-34-512-005 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG MW-3

| Material | Water Strata | From | To | Thickness |
|-----------------------------|--------------|-------------|-------------|------------|
| <u>Asphalt</u> | | <u>0</u> | <u>6"</u> | |
| <u>Type II Fill</u> | | <u>6"</u> | <u>2'</u> | |
| <u>Silty clay w/ gravel</u> | | <u>2'</u> | <u>11'</u> | |
| <u>Caliche</u> | | <u>11</u> | <u>12.5</u> | <u>1.5</u> |
| <u>Sandy clay</u> | <u>17</u> | <u>12.5</u> | <u>25</u> | |

8. WELL CONSTRUCTION
 Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)
 From 8 Inches To 25 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| <u>2"</u> | <u>PVC</u> | <u>sch 40</u> | <u>0</u> | <u>25</u> |

Perforations:
 Type perforation Factor slot
 Size perforation .020
 From 5 feet to 25 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 3 to surface Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 3 feet to 25 feet

9. WATER LEVEL
 Static water level 17 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Elite Drilling Inc.
 Address 5115 S. Industrial rd #104
Las Vegas, NV 89118
 Nevada contractor's license number issued by the State Contractor's Board 0054931
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1869
 Signed _____
 By driller performing actual drilling on site or contractor
 Date 12-30-03

Date started NOV 11, 2003
 Date completed NOV 11, 2003

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------|-------------------------------|--------------|
| | | |
| | | |
| | | |

DCNR/DWR
 RECEIVED
 DEC 30 2003
 LAS VEGAS OFFICE