

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 49370

1. OWNER Cynthia Ashe ADDRESS AT WELL LOCATION 5645 PEEK AVE.
 MAILING ADDRESS _____ SILVER SPRINGS, NV
LYON County
 2. LOCATION NW 1/4 SE 1/4 Sec 2 T 17 N/S R 24 E
 PERMIT NO. 117-016-03 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
DIRT-ROCK		0	32	32
BROWN CLAY-GRAVEL		32	92	60
BLACK FRAC ROCK		92	135	43
GRAY-WHITE ROCK		135	315	
BLACK FRAC ROCK		315	500	

8. WELL CONSTRUCTION

Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>10 5/8</u>	0	75		
<u>9 5/8</u>	75	135		
<u>8 3/4</u>	135	340		
<u>6 7/8</u>	340	500		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>14</u>	<u>1.88</u>	<u>±1</u>	<u>340</u>
<u>5</u>		<u>1.88</u>		<u>500</u>

Perforations:
 Type perforation Factory milled
 Size perforation 3/32" X 3"
 From 320 feet to 340 feet
 From 360 feet to 380 feet
 From 420 feet to 440 feet
 From 480 feet to 500 feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 53 ft Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 53 ft feet to 340 feet

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality CLEAR

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Blain Drilling & Pump Co.
P.O. Box 1255
 Address Carson City, NV 89702
 Nevada contractor's license number issued by the State Contractor's Board 46498
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167
 Signed Jack Dotson
 By driller performing actual drilling on site or contractor
 Date _____

Date started 27 MAY, 2003
 Date completed 6 JUNE, 2003

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>2-3</u>		<u>5.5</u>

RECEIVED
 03 JUL 16 PM 2:31
 STATE ENGINEERS OFFICE