By church

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91616
Permit No.
Basin 102

NOTICE OF INTENT NO. 49008

1. OWNER Laverne Perry
MAILING ADDRESS

ADDRESS AT WELL LOCATION 6435 Elm St. Silver Springs, NV. 89429

2. LOCATION SE ¼ NE ¼ Sec. 12 T. 17 N/S R. 24 E. Lyon County
PERMIT NO. Issued by Water Resources | Parcel No. 17-131-08 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☑ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	14	
Tan clay		14	23	
Sand Cones		23	63	
Gray clay		63	115	
Sand		115	120	
Brown clay		120	124	
Sand some Gravel	✓	124	140	

RECEIVED
03 JUL 14 PM 12:55
STATE ENGINEERS OFFICE

Date started 6-21, 2003
Date complated 6-22, 2003

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Produced about		20	GPM

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.00	3/16	+1	20
6 5/8	13.00	SCH 5 [illegible]	20	140

Perforations:
Type perforation Skill Saw
Size perforation 1/4 x 6 Long Slots
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal: 0-50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 76 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leah Drilling Inc
Contractor
Address PO Box 544
Contractor
Silver Springs NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 787
Signed [signature]
By driller performing actual drilling on site or contractor
Date 6-23-07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627