GEN-4D

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91623
Permit No.
Basin 090

NOTICE OF INTENT NO. 46066

1. OWNER Mary Ann Ferguson
MAILING ADDRESS 774 Mays Blvd Pmb #211
Reno, NV 89451

ADDRESS AT WELL LOCATION 560 Lakeshore Blvd
Incline Village, NV

2. LOCATION NE ¼ SE ¼ Sec. 17 T. 16 N/S R. 18 E. Washoe County

PERMIT NO. ____ Issued by Water Resources | 123-128-07 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
gravel + fill		0	7	
decomposed granite		7	48	
granite boulder		48	57	
D.G.		57	90	

RECEIVED
03 JUL 10 AM 10:57
STATE ENGINEERS OFFICE

Date started 6/24/03, 19
Date completed 6/25/03, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 90 Feet Depth Cased 90' Feet

HOLE DIAMETER (BIT SIZE)
8 Inches From 0 Feet To 90 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	sch 40	PVC	0	70

Perforations:
Type perforation factory slotted
Size perforation .020
From 70 feet to 85 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 65
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 85 feet to 68 feet

9. WATER LEVEL
Static water level 67' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Board Longyear Contractor
Address Box 1000 Contractor
Dayton, NV 89403
Nevada contractor's license number issued by the State Contractor's Board 0010157
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2198
Signed [signature] By driller performing actual drilling on site or contractor
Date 6/26/03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627