



Log No. 91635
 Permit No. _____
 Basin 089

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 50405

1. OWNER VICTOR MASI ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 165 Karnak Cir. 275 Finch
Sparks, Nevada 89436 Carson City, Nevada 89704
 2. LOCATION N 1/4 SW 1/4 Sec 32 T 17N N/S R 20 E Washoe County
 PERMIT NO. 050-395-11 Washoe Valley Sierra #1 Lot 29
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1	1
Brown fine sand		1	44	43
Brown sandy clays, some gravels		44	65	21
Fine rusty sand		65	69	4
Brown sandy clays		69	80	11
Decomposed granite		80	95	15
Weathered granite		95	129	34
Soft decomposed granite		129	133	4
Fractured granite		133	244	111
Fractured zone	X	244	261	17
Gray hard granite		261	280	19
Weathered granite		280	293	13
Rusty brown granite		293	322	29
Fracture granite, soft (NO WATER)		322	360	38
Hard gray granite		360	376	16
Rusty yellow granite		376	384	8
Gray granite		384	443	59
Fracture granite	X	443	461	18
Gray granite		461	473	12

8. WELL CONSTRUCTION
 Depth Drilled 473 Feet Depth Cased 473 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 473 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>0</u>	<u>473</u>

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 358 feet to 368 feet
 From 428 feet to 468 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50 feet
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 473 feet

9. WATER LEVEL
 Static water level 131 feet below land surface
 Artesian flow 20+ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

Date started 5-27-03 19____
 Date completed 6-03-03 19____

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>20+</u>			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510 Contractor
 Nevada contractor's license number 0022549
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 923
 Division of Water Resources, the on-site driller
 Signed [Signature]
 by driller performing actual drilling on site or contractor
 Date June 5, 2003