WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91675
Permit No.
Basin 049

NOTICE OF INTENT NO. 49016A

1. OWNER MIKE ADKINS
MAILING ADDRESS 336-3 OSINO
ELKO, NV 89801

ADDRESS AT WELL LOCATION SO. END OF ZUNI AVE

2. LOCATION SW 1/4 SW 1/4 Sec. 9 T 35N N/S R 56E E ELKO County
PERMIT NO. Issued by Water Resources
035-061-007 Parcel No.
MEADOW VALLEY RANCHO #3 Subdivision Name

3. **WORK PERFORMED**
New Well ☐ Replace ☐ Recondition
Deepen ☒ Abandon ☐ Other

4. **PROPOSED USE**
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. **WELL TYPE**
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
PERFORATE WITH HOLTE AIR PERFORATOR FROM 100 TOO 240 FEET. 4 PERFORATIONS PER ROW AND 4 ROWS. PUMP BENTONITE GROUT FROM 20-260 FEET USING 12 BAGS OF ABANDONITE MIXED WITH 420 GALLONS OF WATER. CEMENT 0-20 WITH NEAT CEMENT				

RECEIVED 03 JUN 19 PM 12:28 STATE ENGINEER'S OFFICE

Date started 6/13/2003 , 19__
Date completed 6/13/2003 , 19__

7. **WELL TEST DATA**
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. **WELL CONSTRUCTION**
Depth Drilled _____ Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	260

Perforations:
Type perforation HOLTE PERFORATED
Size perforation 3/16 X 1
From 100 feet to 240 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From _____ feet to _____ feet

9. **WATER LEVEL**
Static water level 150 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC (Contractor)
Address P.O.BOX 850 (Contractor)
ELKO,NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 6/13/2003

USE ADDITIONAL SHEETS IF NECESSARY