WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91699
Permit No. 70495-T
Basin 230

NOTICE OF INTENT NO. 23646

1. OWNER Morris Delee Revocable Trust
MAILING ADDRESS 12219 Business park drive #14 Trukee, Ca
ADDRESS AT WELL LOCATION A point from which the west 1/4 corner of section 30 bears 5' 04" 01' 45" W a distance of 808 feet

2. LOCATION SW 1/4 NW 1/4 Sec. 30 T. 16 N/S R 49 E Nye County
PERMIT NO. 70495-t (Issued by Water Resources) | 19-131-10 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
~~Cemented gravel~~				
Top soil		0	12	12
Cemented gravel		12	45	33
gravel & clay		45	55	10
Sand & gravel		55	130	75
limestone & clay		130	140	10
gravel		140	160	20
gravel & limestone		160	175	15
gravel & clay		175	185	10
Sand, gravel & clay		185	275	90
Clay		275	295	20
Broken sandstone		295	325	30
limestone & clay		325	345	20
Sandy clay		345	360	15
gravel & clay		360	385	15
Clay		385	425	40
Sand & gravel		425	460	35
Sand		460	480	20
Sandy clay		480	500	20

CONF/DWR
RECEIVED
NOV 1 2003
LAS VEGAS OFFICE

Date started 10-27, 2003
Date complated 11-6, 2003

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
1500	129	3
1200	86	9

8. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 500 Feet

HOLE DIAMETER (BIT SIZE)
22 Inches From 0 Feet To 500 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14		.250	+1	500

Perforations:
Type perforation double row saw cut
Size perforation 3/16 X 3
From 97 feet to 500 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 53
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 53 feet to 500 feet

9. WATER LEVEL
Static water level 115 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature warm F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name American Drilling & pump Service (Contractor)
Address Calahan st. (Contractor)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 0020578
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1161
Signed [signature] By driller performing actual drilling on site or contractor
Date 11-6-03

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627