WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91700
Permit No. 66152
Basin 230

NOTICE OF INTENT NO. 23648

1. OWNER Pondersa Dairy
MAILING ADDRESS P.O. Box 70
Amargosa, NV 89020

ADDRESS AT WELL LOCATION G Ranch Road
Amargosa NV 89020

2. LOCATION NW ¼ SW ¼ Sec. 15 T. 17 N/S R. 49 E. Nye County
PERMIT NO. 66152 (Issued by Water Resources) | 19-701-06 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
topsoil		0	7	
conglomerated rock		7	65	
limestone w/ clay		65	75	
Cemented Gravel		75	95	
gravel w/ clay		95	115	
limestone w/ clay		115	145	
clay w/ gravel		145	155	
clay		155	170	
Sandstone		170	180	
clay		180	210	
clay w/ Sandstone		210	230	
limestone w/clay		230	240	
clay		240	315	
Clay w/Sandstone		315	340	
clay		340	395	
Sandy clay		395	415	
clay		415	498	

DCNR/DWR RECEIVED NOV 2003 LAS VEGAS OFFICE

Date started 10-7, 2003
Date completed 10-23, 2003

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
1900	167	1
1200	87	24

8. WELL CONSTRUCTION
Depth Drilled 498 Feet Depth Cased 498 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
22	0	498

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14		.250	+1	498

Perforations:
Type perforation Saw cut Slotted (double row)
Size perforation 3/16" x 3"
From 54 feet to 498 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 53
Placement Method: ☐ Pumped ☒ Poured

Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 53 feet to 498 feet

9. WATER LEVEL
Static water level 83 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 78 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name American Drilling & pump Service (Contractor)
Address 3040 Colbhan st. (Contractor)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 0020578
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1161
Signed (By driller performing actual drilling on site or contractor)
Date 11-6-03

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627