WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91740
Permit No.
Basin 093

NOTICE OF INTENT NO. 48422

1. OWNER CHRISTOPHER J. JOHNSON
MAILING ADDRESS 9835 Tiberius Ct.
Reno, Nevada 89506

ADDRESS AT WELL LOCATION 2195 Argonaught Way
Reno, Nevada 89506

2. LOCATION SE ¼ SE ¼ Sec. 26 T. 22N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 076-460-01 (Parcel No.) Antelope Valley (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown sandy clays, some decomposed granite		1	34	33
Decomposed granite		34	39	5
Brown sandy clays		39	134	95
Soft zone, decomposed granite sands		134	143	9
Brown sandy clays		143	169	26
Soft zone, fine sands		169	177	8
Brown sandy clays		177	191	14
Weathered granite		191	243	52
Soft zone	X	243	256	13
Weathered granite		256	276	20
Soft zone	X	276	297	21
Weathered granite		297	300	3

RECEIVED
03 JUL -8 AM 10:41
STATE ENGINEERS OFFICE

Date started 6-25-03, 19
Date completed 6-27-03, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	300 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	300

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 236 feet to 256 feet
From 276 feet to 296 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 feet
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 300 feet

9. WATER LEVEL
Static water level 139 feet below land surface
Artesian flow 20 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 0022549

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed (By driller performing actual drilling on site or contractor)
Date July 7, 2003

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627