WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91742
Permit No.
Basin 76

NOTICE OF INTENT NO. 49007

1. OWNER Co/ Investments
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1875 Vine Court

2. LOCATION NW ¼ NE/NW Sec. 36 T. 20 N/S R. 25 E. Lyon County
PERMIT NO. 21-307-05 (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☑ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil		0	1	
Clay		1	37	
Tan clay with some Rock		37	97	
Cemented Gravel		97	323	
Gravel Sand		323	330	
Tan clay		330	354	
Sand Clay mix		354	400	
Sand Clay mix		400	431	
Clay		431	483	
Sand Gravel		483	530	

RECEIVED 03 JUL 14 PM 5:56 STATE ENGINEERS OFFICE

Date started 6-29, 2003
Date completed 7-1, 2003

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
produced about 10		6 hrs

8. WELL CONSTRUCTION
Depth Drilled 530 Feet Depth Cased 530 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
18 5/8 Inches	0 Feet	60 Feet
7 7/8 Inches	60 Feet	400 Feet
6 1/8 Inches	400 Feet	530 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.00	3/16	H	400
5	9.00	3/16	390	530

Perforations:
Type perforation mill slot
Size perforation 40
From 340 feet to 360 feet
From 390 feet to 400 feet
From 430 feet to 450 feet
From 470 feet to 490 feet
From 510 feet to 530 feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☑ Concrete Grout
Gravel Packed: ☐ Yes ☑ No
From feet to feet

9. WATER LEVEL
Static water level 340 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling INC (Contractor)
Address PO Box 579 (Contractor)
Silver Springs NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031391
Nevada driller's license number issued by the Division of Water Resources, the on-site driller
Signed (By driller performing actual drilling on site or contractor)
Date 7-1-03

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627