WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91744
Permit No.
Basin 093

NOTICE OF INTENT NO. 48427

1. OWNER RICHARD & SHERI CAROTHERS
MAILING ADDRESS 9225 Freemont Way
Reno, Nevada 89506

ADDRESS AT WELL LOCATION 2950 Scowens
Reno, Nevada 89506

2. LOCATION NW ¼ NE ¼ Sec. 14 T. 22N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 079-481-45 (Parcel No.) AntelopeSValley (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown sandy clay		1	60	59
Decomposed granite		60	63	3
Brown sandy clay		63	90	57
Soft zone		90	93	3
Brown sandy clay		93	115	22
Soft zone, medium sands		115	119	4
Weathered granite		119	190	71
Fracture	X	190	193	3
Weathered granite		193	209	16
Fracture	X	209	214	5
Weathered granite		214	223	9

RECEIVED 03 JUL 28 AM 11:17 STATE ENGINEERS OFFICE

Date started July 22, 2003, 19
Date completed July 24, 2003, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		

8. WELL CONSTRUCTION
Depth Drilled 223 Feet Depth Cased 223 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	50	Feet
8 5/8	Inches	50	Feet	223	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	223

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 177 feet to 217 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50 feet
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 223 feet

9. WATER LEVEL
Static water level 80 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed (By driller performing actual drilling on site or contractor)
Date July 24, 2003

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627