WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.840

OFFICE USE ONLY
Log No. 91750
Permit No.
Basin 071

NOTICE OF INTENT NO. 48620

1. OWNER Bill Elliott
MAILING ADDRESS 7105 Sunset
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION 7105 Sunset

2. LOCATION NE 1/4 NW 1/4 Sec. 13 T 35N N/S R 37E E Humboldt County
PERMIT NO. _____ Issued by Water Resources | 13-523-04 Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other _____

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sand		0	10	
sand & gravel		10	30	20
coarse gravel w/clay		30	75	45
white clay		75	80	5
sand		80	100	20
gravel & clay		100	125	25
basalt		125	135	10

RECEIVED
03 JUL 28 AM 11:17
STATE ENGINEERS OFFICE

Date started 7/18/03, 19__
Date completed 7/18/03, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		2 hrs

8. WELL CONSTRUCTION
Depth Drilled 135 Feet Depth Cased 130 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 Inches	0 Feet	135 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8		.188	+1	100

Perforations:
Type perforation mill slot
Size perforation .90
From 100 feet to 130 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 59
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 59 feet to 130 feet

9. WATER LEVEL
Static water level 82 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4675 W. Winnemucca Blvd (Contractor)
Winnemucca, Nevada 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713

Signed [signature] (By driller performing actual drilling on-site or contractor)

Date 7/26/03