WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91753
Permit No.
Basin 095

NOTICE OF INTENT NO. 48426

1. OWNER: BOB & LINDA DAVIS
MAILING ADDRESS: 4016 Sycamore Way, Reno, Nevada 89502
ADDRESS AT WELL LOCATION: Marie Way, Sparks, Nevada 89436

2. LOCATION: NW ¼ SW ¼ Sec. 4 T. 20N N/S R. 20 E. Washoe County
PERMIT NO. (Issued by Water Resources) 083-440-62 (Parcel No.) Spanish Springs (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown sandy clays		1	6	5
Soft sandy clays with gravel & some boulders		6	9	3
Brown sandy clays		9	49	40
Soft zone, brown sand		49	51	2
Brown sandy clays		51	93	42
Soft zone		93	96	3
Brown sandy clays		96	155	59
Brown sticky clay		155	159	4
Brown sandy clays		159	244	85
Soft zone		244	249	5
Brown sandy clays		249	280	31
Weathered granite		280	389	109
Fractured granite	X	389	416	27
Weathered granite		416	423	7

RECEIVED 03 JUL 28 AM 11:17 STATE ENGINEERS OFFICE

Date started: July 16, 2003, 19
Date completed: July 21, 2003, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
22		

8. WELL CONSTRUCTION
Depth Drilled 423 Feet Depth Cased 423 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	423 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	423

Perforations:
Type perforation: factory sawed slot
Size perforation: 3/32 x 3 x 5 around
From 377 feet to 417 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal: 50 feet
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 423 feet

9. WATER LEVEL
Static water level: 255 feet below land surface
Artesian flow: G.P.M. P.S.I.
Water temperature: cold °F Quality: clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name: WAYNE DRILLING, INC. (Contractor)
Address: P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board: 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 923
Signed: [signature] (By driller performing actual drilling on site or contractor)
Date: July 24, 2003

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627