WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91763
Permit No. 70023-T
Basin 72

NOTICE OF INTENT NO. 49209

1. OWNER Florida Canyon Mining Inc
MAILING ADDRESS P.O. Box 330
Imlay Nevada, 89418
ADDRESS AT WELL LOCATION

2. LOCATION NE ¼ SW ¼ Sec. 35 T. 31 N/S R. 33 E. Pershing County
PERMIT NO. 70023-T (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☑ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☒ Other Stradex

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders And soil		0	35	
Limestone (hard)		35	43	
Brown Clay		43	50	
Limestone - Pink		50	88	
Limestone - Gray		88	92	
Limestone - Pink		92	105	
Fractured Limestone	✓	105	145	
Clay - Brown		145	150	
Fractured Limestone		150	190	
loose, rounded gravel	100 gpm	190	215	
Limestone - Hard gray		215	220	
Fractured Limestone	✓	220	240	
Rounded 3/4 gravel	200 gpm	240	250	
Limestone - Blue-gray	✓	250	260	
Fractured Limestone	✓	260	270	
Limestone Blue-Gray		270	300	
loose 3/4 rounded	✓	300	310	
Fractured Limestone	✓	310	340	
Brown-Orange		340	350	
Oxyidized Limestone				
Gray-Black Limestone		350	360	
with mica & Quartz				
Black Rounded	400 gpm	360	400	
Limestone /with Quartz				
Black Limestone with		410	416	
Gnafite film				

Date started 11-5-03, 19__
Date completed 12-15-03, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
400		4

8. WELL CONSTRUCTION
Depth Drilled 416 Feet Depth Cased 416 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
26 Inches	0 Feet	36 Feet
19" Inches	36 Feet	120 Feet
12 Inches	120 Feet	416 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
20		.25	+1	36
12		.25	+1.5	416

Perforations:
Type perforation Star Perforator (Air)
Size perforation 8 rows (1/4 x 1)
From 145 feet to 410 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 120 feet

9. WATER LEVEL
Static water level 140 feet below land surface
Artesian flow Ø G.P.M. ____ P.S.I.
Water temperature COLD °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration (Contractor)
Address P.O. Box 141 (Contractor)
Zamora Calif. 95698
Nevada contractor's license number issued by the State Contractor's Board 0012852
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2244
Signed Randy Cuiner (By driller performing actual drilling on site or contractor)
Date 1-10-04

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627