WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91773
Permit No.
Basin 105

NOTICE OF INTENT NO. 46083

1. OWNER Bentley Agrodynamics
MAILING ADDRESS P.O. Box 157
Minden, NV 89423

ADDRESS AT WELL LOCATION Bentley Middle Ranch House Area

2. LOCATION NW ¼ SW ¼ Sec. 14 T. 13 N/S R. 20 E County
PERMIT NO. (Issued by Water Resources) 1320-14-002-002 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other SONIC

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND + GRAVEL		0	15	15
lightly cemented GRAVEL		15	45	30
SAND + GRAVEL		45	60	15
GRAVEL (MIX)		60	70	10
Light SAND + GRAVEL	70'	70	80	10
silty SAND		80	87	7
SAND + GRAVEL		80	97	17
BACKFILL				
3/8 Bentonite chips from 97 to 87				

Date started 1/8/, 2004
Date completed 1/9/, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8" Inches	0 Feet	97 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"		sch. 40	0	47

Perforations:
Type perforation: Factory slotted
Size perforation: .010
From 47 feet to 87 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 45
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 87 feet to 45 feet

9. WATER LEVEL
Static water level 55 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of ~~my knowledge~~.
Name Bonet Longyear (Contractor)
Address P.O. Box 1000 (Contractor)
Dayton, NV 89403
Nevada contractor's license number issued by the State Contractor's Board 0010157
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2198
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 1/12/04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627