

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 46082

1. OWNER Bentley Agrow Dynamics
 MAILING ADDRESS P.O. Box 127 Minden, NV 89423
 ADDRESS AT WELL LOCATION NEAR NEW Bentley RES. site Minden, NV
 2. LOCATION SW 1/4 SE 1/4 Sec. 24 T. 13 N. R. 30 E County
 PERMIT NO. 13-20-24-002-006 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other: Septic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
small gravel, cobbles		0	20	20
small gravel, small c. my pebbles		20	38	18
small, small gravel		38	58	20
common fine gravel		58	66	8
clayey sand		66	90	24
gravel		90	100	10
sand	100'	100	120	20
sand & gravels		120	160	40
Backfill				
3/8 Bentonite chips from 160' to 147'				

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 147 Feet
 HOLE DIAMETER (BIT SIZE)
 8" From 0 To 147 Feet
 Inches 0 Feet 147 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"		sch 40	0	87

Perforations:
 Type perforation Factory slotted
 Size perforation .018
 From 87 feet to 147 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 8' 8"
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 85 feet to 147 feet

9. WATER LEVEL
 Static water level 10.3 feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature °F Quality

Date started 1/5 2024
 Date completed 1/7 2024

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name: Boart Longyear Contractor
 Address: P.O. Box 1000 Dayton NV 89403 Contractor
 Nevada contractor's license number issued by the State Contractor's Board: 0010157
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: M-2198
 Signed: [Signature] By driller performing actual drilling on site or contractor
 Date: