WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91779
Permit No.
Basin 107

NOTICE OF INTENT NO. 48956

1. OWNER Ray Van Winkle
MAILING ADDRESS P.O. Box 181 Wellington Nev 89444
ADDRESS AT WELL LOCATION No 1 Valley View Estates Wellington Nev. 89444

2. LOCATION E ½ W ½ Sec. 10 T. 11 N/S R. 23 E. Lyon County
PERMIT NO. Issued by Water Resources | Parcel No. 9-061-01 | Subdivision Name Valley View Estates

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
top soil		0	3	3
Hard pan		3	7	4
alluvial D-G + brown clay		7	78	71
Coarse sand + pea gravel	✓	78	125	47
brown clay		125	136	11
Coarse sand	✓	136	155	19
fine sand		155	160	5
Coarse pea gravel	✓	160	180	20
fine sand	✓	180	185	5

Date started Nov 27 2003
Date completed Dec 2 2003

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☑ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	20	3 hrs

8. WELL CONSTRUCTION
Depth Drilled 185 Feet Depth Cased 185 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	60 Feet
6 5/8 Inches	60 Feet	185 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		188	0	185

Perforations:
Type perforation factory saw slott
Size perforation 3/32 x 3
From 125 feet to 185 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 60 ft
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☑ No
From feet to feet

9. WATER LEVEL
Static water level 95 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edmund Miller Drilling Contractor
Address P.O. Box 92 Contractor
Smith Nev. 89730
Nevada contractor's license number issued by the State Contractor's Board 32166-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edmund Miller
By driller performing actual drilling on site or contractor
Date Dec 6-03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627