COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91781
Permit No.
Basin 106
NOTICE OF INTENT NO. 46430

1. OWNER RON LEE
MAILING ADDRESS SILVER CITY RV RESORT
CARSON CITY , NV 89701

ADDRESS AT WELL LOCATION 1566 ALBA VISTA DR
GARDNERVILLE , NV 89410

2. LOCATION ~~NW~~ ¼ ~~NW~~ ¼ Sec 18 T 10 N R 22 E DOUGLAS County

PERMIT NO. SE SW (Issued by Water Resources) | 1022-18-002-049 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| OVERBURDEN CLAY | | 0 | 3 | 3 |
| SMALL GRAVELS | | 3 | 18 | 15 |
| BLUE GRANITE SHELF | | 18 | 27 | 9 |
| COURSE GRAVELS | | 27 | 156 | 129 |
| CLAY SEAMS | | | | |
| BROWN CLAY SEAM | | 156 | 194 | 38 |
| FRACTURED GRAVELS | | 194 | 240 | 46 |
| COLORED FRACTURE OBSIDIAN GRTAVELS | XXX | 240 | 260 | 20 |

Date started 5-15 , 20 03
Date completed 5-19 , 20 03

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 18 | 65 | 3 HRS |

8. WELL CONSTRUCTION

Depth Drilled 260' Feet Depth Cased 260' Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10 3/4 Inches | 0 Feet | 260 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 13.03 | .188 | 0 | 260 |

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3 X 3/32
From 240 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50 ☒ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☒ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 260 feet

9. WATER LEVEL
Static water level 120 feet below land surface
Artesian flow G.P.M 18 P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING INC. (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY , NV 89706
Nevada contractor's license number issued by the State Contractor's Board 55548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 5-22-03