COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91783
Permit No.
Basin 106

NOTICE OF INTENT NO. 46431

1. OWNER DON & VICKY YOUNGMAN
MAILING ADDRESS SILVER CITY RV RESORT
CARSON CITY, NV 89701

ADDRESS AT WELL LOCATION 1580 ALBA VISTA DR
GARDNERVILLE, NV 89410

2. LOCATION ~~NW~~ ¼ ~~NW~~ ¼ Sec 18 T 10 N R 22 E DOUGLAS County
PERMIT NO. SE SW (Issued by Water Resources) 1022-18-002-034 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN CLAY		0	3	3
SMALL GRAVELS		3	18	15
BLUE GRANITE SHELF		18	27	9
COURSE GRAVELS		27	156	129
CLAY SEAMS				
BROWN CLAY SEAM		156	194	38
FRACTURED GRAVELS		194	240	46
COLORED FRACTURE OBSIDIAN GRTAVELS	XXX	240	260	20

RECEIVED 03 AUG 13 AM 10:47 STATE ENGINEER'S OFFICE

Date started 7/7, 20 03
Date completed 7/10, 20 03

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
22	65	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 260' Feet Depth Cased 260' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	260 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	260

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3 X 3/32
From 240 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Placement Method: ☐ Pumped ☒ Poured
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 260 feet

9. WATER LEVEL
Static water level 120 feet below land surface
Artesian flow G.P.M 18 P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING INC. (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 55548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 7/15/03

Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9429