

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 91797
 Permit No. _____
 Basin 102

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **48699**

OWNER Sherry Powell ADDRESS AT WELL LOCATION 8340 Clifton Rd, Silver Springs, Nv. 89429
 MAILING ADDRESS 8340 Clifton Ave. Silver Springs, NV 89429
 2. LOCATION SW 1/4 NE 1/4 Sec. 21 T 17 N/S R 25 E Lyon County
 PERMIT NO. 017-502-13 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other
 4. PROPOSED USE
 Domestic Municipal/Industrial Irrigation Monitor Test Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
blow sand		0	12	12
brown sand		12	17	5
clay/sand		17	25	8
clay		25	40	15
fine sand		40	60	20
clay/sand		60	80	20
fine sand		80	100	20
fine sand		100	120	20
clay		120	135	15
sand and gravel		135	140	5
clay		140	150	10
sand brown		150	153	3
clay		153	155	2
sand and gravel	xx	155	178	23

8. WELL CONSTRUCTION
 Depth Drilled 178 Feet Depth Cased 178 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 inches To 0 Feet 178 Feet
 _____ inches _____ Feet _____ Feet
 _____ inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	20
6pvc	3.92	.258	20	178

Perforations:
 Type perforation saw cut
 Size perforation 1/8
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 100
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 178 feet

9. WATER LEVEL
 Static water level 20 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Parsons Drilling, Inc. Contractor
 Address P.O. Box 1265 Contractor
Fallon, Nv. 89407-1265
 Nevada contractor's license number issued by the State Contractor's Board 29064
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1454
 Signed Norman Parsons
 By driller performing actual drilling on-site or contractor
 Date 8/25/2003

Date started 7/24/2003, 19____
 Date completed 7/25/2003, 19____

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50</u>		<u>1hr</u>

RECEIVED
 03 SEP 10 AM 11:04
 STATE ENGINEERS OFFICE