

009314

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91809
Permit No. _____
Basin. 212

NOTICE OF INTENT NO. 25813

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

1. OWNER BOTS DENINO ADDRESS AT WELL LOCATION _____
MAILING ADDRESS P.O. Box 711 1215 E STEWART AVE
DALLAS, TX 75221 LAS VEGAS, NV
2. LOCATION S1/4 NW 1/4 Sec. 35 T. 20 N/S R. 61 E CLARK County
PERMIT NO. 139-35-211-092 Subdivision Name _____
Issued by Water Resources Parcel No. _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Type II Fill		00	20	20
Sandy clay		20	80	60
silty sand		80	120	40
Sandy, Gassy clay		120	200	80

8. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 20 Feet
HOLE DIAMETER (BIT SIZE)
From To
11 1/2 Inches 00 Feet 200 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.250</u>		<u>Sch 40 PVC</u>	<u>500</u>	<u>00</u>

Perforations:
Type perforation MACHINE SLOTTED
Size perforation .020
From 50 feet to 200 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 1' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 20 feet to 30 feet

9. WATER LEVEL
Static water level 12.5' feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EAGLE DRILLING SERVICES Contractor
Address 7150 Phoe St. Contractor
LAS VEGAS, NV 89119
Nevada contractor's license number 51266
issued by the State Contractor's Board.
Nevada driller's license number issued by the 2202
Division of Water Resources, the on-site driller.
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 12/24/03

Date started 12/12, 2003
Date completed 12/12, 2003

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

DO NOT WRITE
RECEIVED
LAS VEGAS OFFICE