A03.083

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 9/821
PERMIT NO.
TASK 083

NOTICE OF INTENT NO. 51437

Contact: Scott Saunders
Address: 2065 Apple Gate Rd. VCH, NV 89521

Address of Well: 2065 Apple Gate Rd.
Virginia City Highlands, NV 89521

SE NE 32 18 N 21 E Storey County

APN: 003-092-38 SUBDIVISION NAME

USE OF WELL: New well / Replacement / Observation / Monitoring / Test / Domestic / Irrigation / Stock / Municipal / Industrial / Monitor / Stock / X / Other / Mine

LITHOLOGY	Water Bearing	FROM	TO	Thickness
Soft Fill Course Sand Granite		348	370	22
Salt Pepper Granite	X	370	420	50
Pine Green Hard Rock	X	420	457	37

WELL CONSTRUCTION

Depth Drilled 457 Depth Cased 457

HOLE DIAMETER (BIT SIZE)

8 inches 348 Feet 457 Feet
inches Feet Feet
inches Feet Feet

CASING PROFILE

Size O.D.	Weight/Ft	Wall Thickness	From	To
5	9.62	.188	257	457

PERFORATIONS

Type Perforation Factory Size/Number/Spacing 3/32 X 3

From 417 To 457 Feet
From To Feet
From To Feet

SURFACE SEAL Yes No Depth Type
Neat Cement
Neat Grout Cement Grout
PLACEMENT METHOD Pumped Concrete Grout
Poured Bentonite

GRAVEL PACKED Yes No

From To Feet

Note:

WATER LEVEL

Static Water Level 268 Feet Below Land Surface
Artesian Flow GPM PSI
Water Temperature cool Quality clear

Date Started 8-24-03 Date Completed 8-28-03

WELL DRILLER'S CERTIFICATION

This well was drilled under my supervision and this report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc.
Address 875 Edison Way Reno, NV 89502

NV CONTRACTOR'S LIC. NO. 15001 Date 2499

Signature Regenthaly

Dated August 28, 2003

WELL TEST DATA

X Air Develop

Pump	Discharge	Type Test
20+		1hr.

RECEIVED
03 SEP -4 AM 11:15
STATE ENGINEER'S OFFICE