

REPORT NO. A03.055

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

LOG NO. 91823
PERMIT NO. _____
BASIN 90

NOTICE OF INTENT NO. 48871

1. OWNER Round Hill General Improvement District ADDRESS OF WELL 205 Elks Point Rd.
MAILING ADDRESS P.O. Box 976 Zephyr Cove, NV 89448 Zephyr Cove, NV
2. WELL LOCATION SW 1/4 SE 1/4 SEC. 15 T 13 R 18 E Douglas COUNTY
PERMIT NO. 69576T PARCEL NO. 131815803005 SUBDIVISION NAME _____

3. TYPE OF WORK

New Well Replace Recondition
 Deepen Plug Other

4. PROPOSED USE

Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE

Cable Rotary RVC
 Air Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Granite, sand, DG		0	104	104
SP greenish silt, green granite		104	235	131
Little rust color, SP granite		235	270	35
Yellow DG, SP granite		270	280	10
SP granite		280	285	5
DG, SP granite		285	325	40
Fractured DG		325	330	5
Harder DG		330	375	45
SP granite, DG fractured in and out all the way from		375	460	85
Hard granite		460	466	6

8. WELL CONSTRUCTION

Depth Drilled 466 Depth Cased 466
HOLE DIAMETER (BIT SIZE)
12" Inches 0 Feet 100 Feet
8" Inches 100 Feet 466 Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
<u>8 5/8"</u>	<u>16.94</u>	<u>.188</u>	<u>+1</u>	<u>104</u>
<u>6 5/8"</u>	<u>12.92</u>	<u>.188</u>	<u>+3</u>	<u>466</u>

PERFORATIONS:

Type Perforation Air Size Perforation perforator
From 140 Feet to 150 Feet
From 330 Feet to 350 Feet
From 400 Feet to 460 Feet

SURFACE SEAL: Yes No SEAL TYPE:
Seal Depth 100 Neat Cement
 Cement Grout
PLACEMENT METHOD: Pumped Concrete Grout
 Poured Bentonite

GRAVEL PACKED: Yes No
From _____ Feet to _____ Feet

Notes: Drilled with mud to 100' & sealed w/ neat cement. Drilled from 100' to 406' with rotary air. Drilled 406' to 466' with Symmetrix.

Date Started 5/22/03 Date Completed 6/6/03

7. WELL TEST DATA

TEST METHOD Bailer Pump Air Develop

	GPM	DRAWDOWN	TIME (HRS)
<u>Air</u>	<u>100+</u>		<u>1 hour</u>

9. WATER LEVEL

Static Water Level 71 Feet Below Land Surface
Artesian Flow _____ GPM _____ PSI
Water Temperature cool F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno, NV 89502

NV. CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO. _____
ON SITE 2189
Signed Roger M. Hall
By driller performing actual drilling on site or contractor
Dated June 6, 2003