


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



OFFICE USE ONLY

Log No. 91824
 Permit No. _____
 Basin 03

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 42901

1. OWNER Lyon County Utilities ADDRESS AT WELL LOCATION Behind Art Wilson Co. property near Linehan Rd. in Moundhouse, NV.
 MAILING ADDRESS P.O. Box 1699 Dayton, NV 89403

2. LOCATION NW 1/4 NE 1/4 Sec. 25 T 16N N/S R 20E E Lyon County
 PERMIT NO. 27204 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Removed 130' of 1-1/2" poly pipe and pump from 10" well. Measured static water level at 27'. Measured depth of well at 148'. Installed bailer but could not retrieve any debris. Installed 10" and perforated from 50' to surface with 5 rows per foot. There was no cement seal around casing. Well did have a 14" conductor casing that was cemented in but while pumping cement, fluid would come around conductor and production casing. After perforating was completed, we installed 147' of 2" tremme pipe and pumped in 6 yards of neat cement. Well volume should have only required 3 cubic yards. MH#11 (original log attached)				
<i>Plugging of log # 15397</i>				
<i>See log 15397 for csg. depth</i>				

8. WELL CONSTRUCTION
 Depth Drilled 150' Feet Depth Cased 150' Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 Inches _____ Feet _____ Feet _____
 Inches _____ Feet _____ Feet _____
 Inches _____ Feet _____ Feet _____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10"		.188"	+1	150'

Perforations:
 Type perforation mill slot and Mills Knife
 Size perforation 1/2"x2"
 From surface feet to 150' feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 150' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 27' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Carson Pump Contractor
 Address P.O. Box 20159 Contractor
Carson City, NV. 89721
 Nevada contractor's license number issued by the State Contractor's Board 39920
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
 Signed Dave Trampe
 By driller performing actual drilling on-site or contractor
 Date 08/06/2003

Date started 08/07/2003, 19____
 Date completed 08/07/2003, 19____

7. WELL TEST DATA

TEST METHOD:	Bailer		Pump		Air Lift	
	G.P.M.	Draw Down (Feet Below Static)	G.P.M.	Draw Down (Feet Below Static)	G.P.M.	Time (Hours)

RECEIVED
 03 AUG 21 AM 10:50
 STATE ENGINEER'S OFFICE