WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.5[illegible]

OFFICE USE ONLY
Log No. 91838
Permit No.
Basin 070

NOTICE OF INTENT NO. 048626

OWNER James Woodward
MAILING ADDRESS 1073 Canal Drive
Gardnerville, NV 89410

ADDRESS AT WELL LOCATION Airport Rd - Winnemucca

2. LOCATION NE 1/4 NE 1/4 Sec. 9 T 35N N/S R 37E E Humboldt County
PERMIT NO. _____ Issued by Water Resources | 013-075-12 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
blow sand		0	1	
silty sand		1	44	43
sand		44	54	10
coarse sand		54	62	8
coarse sand, pea gravel	x	62	89	27
clay		89	92	3
sand/sm. gravel	x	92	135	43
gravel	x	135	150	15

Date started 8/28/03 , 19__
Date completed 8/29/03 , 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50+		1.5 hrs.

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 146 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	150 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6		.188	0	146

Perforations:
Type perforation mill slot
Size perforation .100
From 106 feet to 146 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 150 feet

9. WATER LEVEL
Static water level 63 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4675 W. Winnemucca Blvd (Contractor)
Winnemucca, Nevada 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2235

Signed [signature] (By driller performing actual drilling on-site or contractor)

Date 9/2/03