



Log No. 91843  
 Permit No. \_\_\_\_\_  
 Basin 091

**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

1. OWNER Cliff Corbett ADDRESS AT WELL LOCATION 70 Bitterbrush, Mogul  
 MAILING ADDRESS 119 Vine St.  
Reno, NV 89503

2. LOCATION SW 1/4 NW 1/4 Sec. 14 T 19N N/S R 18E E Washoe County  
 PERMIT NO. 38-341-05 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<b>brown clay, boulders &amp; sand</b>		0	35	35
<b>Brown clay</b>		35	45	10
<b>blue clay</b>	X	45	120	75
<b>Gray clay</b>		120	255	135
<b>Brown clay</b>	X	255	265	10
<b>Gray clay</b>		269	300	35

Dropped liner says Ingrid @ Wayne Drilling  
 Belled top of liner.

*well dugged on 8/25/03  
 log # 91836*

8. WELL CONSTRUCTION  
 Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
<u>10 5/8</u> Inches	<u>0</u> Feet	<u>120</u> Feet
<u>6</u> Inches	<u>120</u> Feet	<u>300</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.156</u>	<u>0</u>	<u>120 ?</u>
<u>5</u>	<u>10.79</u>	<u>.188</u>	<u>100</u>	<u>300</u>

Perforations:  
 Type perforation Factory sawed slot  
 Size perforation 3/32 x 2 1/4 x 6 around

From	To
<u>76</u> feet	<u>300</u> feet
_____ feet	_____ feet
_____ feet	_____ feet
_____ feet	_____ feet
_____ feet	_____ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 300 feet

9. WATER LEVEL  
 Static water level 50 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling, Inc. Contractor  
 Address P.O. Box 12370 Contractor  
Reno, NV  
 Nevada contractor's license number issued by the State Contractor's Board 14043  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed \_\_\_\_\_  
 By driller performing actual drilling on-site or contractor

Date 9/19/78

Date started 9/7/78, 19\_\_\_\_  
 Date completed 9/8/78, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>8</u>		

RECEIVED  
 03 SEP - 2 PM 12:33  
 STATE ENGINEERS OFFICE