WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91844
Permit No.
Basin 87

NOTICE OF INTENT NO. 49329

1. OWNER Bob & Nancy Maddox
MAILING ADDRESS 4045 LaMay
Reno, NV 89511

ADDRESS AT WELL LOCATION 4045 LaMay

2. LOCATION SE 1/4 SE 1/4 Sec. 11 T 18N N/S R 19E E Washoe County
PERMIT NO. (Issued by Water Resources) Parcel No. 040-491-33 Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we abandoned the 8" x 121' domestic well by perforating from 100' to 12' where we hit a sanitary seal. We perforated at 4 around and at one foot intervals using a Mills Knife. We then pumped approximately 2.5 cu. yards neat cement mixed 5.2 gallons/ sack and used tremie pipe and pumped from the bottom to the top. We then cut the casing off approximately 18" below grade.				
Washoe County well permit # WL 030256				

Date started 1/7/2004, 19__
Date completed 1/8/2004, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 121 Feet Depth Cased 121 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	22	.188	0	121

Perforations:
Type perforation Mills Knife
Size perforation Puncture
From feet to feet
From 100 feet to 12 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 121
AF 1-22-04
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Placement Method: ☒ Pumped ☐ Poured

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 81 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 1/8/2004

USE ADDITIONAL SHEETS IF NECESSARY