


KL-#2

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES



OFFICE USE ONLY

Log No. 91848

Permit No.

Basin 87

PRINT OR TYPE ONLY  
NOT WRITE ON BACK

WELL DRILLER'S REPORT  
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 46093

1. OWNER Public Works/City of Reno ADDRESS AT WELL LOCATION West of Sienna St. Along South Side of 3rd Street  
MAILING ADDRESS P.O. Box 1400 Reno, Nevada 89505

2. LOCATION SW 1/4 NE 1/4 Sec. 11 T. 19 S. R. 19 E. Washoe County  
PERMIT NO. DEW-30 Issued by Water Resources Parcel No. 011-370-10 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other None

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Asphalt & Fill		0'	1'	1'
Silty Clay - Reddish Brown		1'	7.5'	6.5'
Silt - Dense - Brown - Dry		7.5'	10'	2.5'
Silty SAND - Brown - DAMP		10'	15'	5'
SAND - small to medium - Dry		15'	19'	4'
Silty Clay - Brown - Dry		19'	24'	5'
Gravelly SAND - Grey - Dry		24'	30'	6'
Gravelly SAND - Grey - Moist	✓	30'	36'	5'

8. WELL CONSTRUCTION  
Depth Drilled 35' Feet Depth Cased 35' Feet  
HOLE DIAMETER (BIT SIZE)  
From 6" Inches To 35' Feet  
Inches Feet Feet Feet  
Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>Sch. 40</u>	<u>P.V.C.</u>	<u>0'</u>	<u>25'</u>

Perforations:  
Type perforation Factory Cut  
Size perforation 0.020"  
From 25' feet to 35' feet  
From feet to feet  
From feet to feet  
From feet to feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 23'  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No 3' Concrete  
From 35' feet to 23' feet

9. WATER LEVEL  
Static water level 32.6' feet below land surface  
Artesian flow No G.P.M. P.S.I.  
Water temperature °F Quality

Date started 1-12- 2004  
Date completed 1-12- 2004

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Phillip Cramer / Boart Longyear Contractor  
Address P.O. Box 1000 Dayton, NV 89403 Contractor  
32 Stokes Dr. Dayton, NV 89403  
Nevada contractor's license number issued by the State Contractor's Board 000157  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2148  
Signed Phillip E. Cramer  
By driller performing actual drilling on site or contractor  
Date 1-15-04