WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91856
Permit No.
Basin 045

NOTICE OF INTENT NO. 45400

1. OWNER DANIEL McCOY
MAILING ADDRESS P.O. BOX 281439
LAMOILLE, NV 89828

ADDRESS AT WELL LOCATION SUNSET ROAD - LAMOILLE, PROPERTIES

2. LOCATION SE 1/4 NE 1/4 Sec. 13 T 33N N/S R 57E E ELKO County
PERMIT NO. 66786 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [X] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SUBSOIL		0	2	2
CLAY		2	8	6
SAND		8	13	5
CLAY		13	19	6
SANDSTONE		19	38	19
CLAY		38	102	64
HARDROCK		102	107	5
CLAY		107	109	2
HARDROCK		109	115	6
LOOSE ROCK	X	115	117	2
CLAY		117	158	41
HARDROCK		158	171	13
CLAY		171	197	26
SOFT SANDSTONE		197	203	6
HARDROCK		203	235	32
LOOSE ROCK	X	235	227	-8
CLAY		227	251	24
VERY HARD ROCK		251	268	17
CLAY		268	273	5
SANDSTONE		273	294	21
LOOSE ROCK	X	294	312	18

Date started 5/27/2003, 19__
Date completed 6/2/2003, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	130		7.5

8. WELL CONSTRUCTION
Depth Drilled 312 Feet Depth Cased 312 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 1/4	Inches	0	Feet	312	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	16.72	188	+1	312

Perforations:
Type perforation MILL SLOT
Size perforation 1/8 X 3
From 110 feet to 130 feet
From 220 feet to 240 feet
From 270 feet to 312 feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 312 feet

9. WATER LEVEL
Static water level 115 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name SHAREL C. FERTIG SR., DBA FERTIG DRILLING CO. (Contractor)
Address P.O. BOX 525 (Contractor)
ELKO, NEVADA 89803
Nevada contractor's license number issued by the State Contractor's Board 0031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed (By driller performing actual drilling on-site or contractor)
Date 6/10/2003

USE ADDITIONAL SHEETS IF NECESSARY