

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
 WELL DRILLER'S REPORT

OFFICE USE ONLY  
 Log No. 918607  
 Permit No. 68730 + 68731  
 Basin 032

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 51173

1. OWNER Nevada First Corp ADDRESS AT WELL LOCATION Silver State Valley  
 MAILING ADDRESS 620 Merlarky  
Winnemucca, NV 89445 N46162997 W117849080

2. LOCATION NE 1/4 NE 1/4 Sec. 19 T 38N N/S R 37E E Humboldt County  
 PERMIT NO. Waiver W-551A Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Silty sand		0	10	
granite sand		10	40	30
silty clay		40	50	10
silty sand		50	65	15
sand & gravel		65	250	185
sandy clay		250	253	3
sand & gravel		253	290	37
sand & clay		290	355	65
coarse sand		355	360	5
clay		360	415	55
clay & sand		415	420	5
br. clay		420	505	85
sand & clay		505	578	73
clay		578	620	42

8. WELL CONSTRUCTION  
 Depth Drilled 620 Feet Depth Cased 600 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
38 Inches 0 Feet 50 Feet  
24 Inches 50 Feet 620 Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
30		conductor	0	50
16		.250	+2	240
16		.250	360	480

Perforations:  
 Type perforation mill slot DR  
 Size perforation .100  
 From 240 feet to 360 feet  
 From 480 feet to 600 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 5 feet to 620 feet

9. WATER LEVEL  
 Static water level 171.5 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. Contractor  
 Address 4675 W. Winnemucca Blvd Contractor  
Winnemucca, Nevada 89445  
 Nevada contractor's license number issued by the State Contractor's Board 015234  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713  
 Signed [Signature]  
 By driller performing actual drilling on-site or contractor  
 Date 6/21/02

Date started 6/18/02, 19\_\_\_\_  
 Date completed 6/20/02, 19\_\_\_\_

7. WELL TEST DATA

P/L	TEST METHOD: <input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>315 ft</u>	<u>600</u>	<u>143.5</u>	<u>7 hrs.</u>