WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91868
Permit No.
Basin 141

No card sent in

NOTICE OF INTENT NO.

1. OWNER BENEDICT BOYD SR. & LILA J. BOYD
MAILING ADDRESS BOX 137
TONOPAH NV 89049

ADDRESS AT WELL LOCATION JB SAND & GRAVEL
RADAR HILL, TONOPAH NV

2. LOCATION SW ¼ NW ¼ Sec. 34 T. 4 N/S R. 43 E. NYE County
PERMIT NO. 64331 Issued by Water Resources | Parcel No. N/A | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☒ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic (INDUSTRIAL) ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
NEVER WAS A WELL LOG TURNED IN. REEMED OUT HOLE, DRILLED OUT OLD CASING, PUT WATER METER IN IT AND PUMPED IT. USED 42 SACKS NEAT CEMENT AND PUMPED IT THROUGH A WATER METER. DUE TO MULTIPLE BREAK DOWNS, JOB DELAYED, REQUIRING EXTENSION.				

Date started APRIL, 2003, 19
Date completed 11-6-03, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift METER

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
300	10 ft	5 hrs

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
17 Inches		0 Feet	80 Feet
[redacted] Inches		— Feet	— Feet
14 1/4 Inches		80 Feet	220 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
[redacted] 8		5/8	0	220
	CERTALOK CASING			

Perforations:
Type perforation SLOT
Size perforation 1/32
From 0 feet to 60 feet
From 60 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 FT
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 50 feet

9. WATER LEVEL
Static water level 106 feet below land surface
Artesian flow 300 G.P.M. P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BENEDICT BOYD, SR (Contractor)
Address BOX 137 (Contractor)
TONOPAH NV 89049
Nevada contractor's license number issued by the State Contractor's Board 0055941-B GEN
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1332
Signed Charles E. Bunning
By driller performing actual drilling on site or contractor
Date 11/21/03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627